

IMPORTANT SAFEGUARDS

When using electrical equipment, basic safety precautions should always be followed including the following:

READ AND FOLLOW ALL SAFETY INSTRUCTIONS

- a) Do not use outdoors.
- b) Do not mount near gas or electric heaters.
- c) Equipment should be mounted in locations and at heights where it will not be subjected to tampering by unauthorized personnel.
- d) The use of accessory equipment not recommended by the manufacturer may cause an unsafe condition.
- e) Do not use this equipment for other than its intended use.
- f) All servicing should be performed by qualified personnel.

SAVE THESE INSTRUCTIONS

CERTIFICATIONS

CE:	BS EN IEC 55015:2019+A11:2020 / EN IEC 55015:2019+A11:2020 BS EN 61547:2009 / EN 61547:2009 BS EN IEC 61000-3-2:2019+A1:2021 / EN IEC 61000-3-2:2019+A1:2021 BS EN 61000-3-3:2013+A1:2019 / EN 61000-3-3:2013+A1:2019 ETSI EN 301 489-1 V2.2.3 (2019-11) ETSI EN 301 489-17 V3.2.4 (2020-09) BS EN IEC 61058-1:2018 / EN IEC 61058-1:2018 BS EN 61058-1-2:2016 / EN 61058-1-2:2016 BS EN 62479:2010 / EN 62479:2010 BS EN 50663:2017 / EN 50663:2017 ETSI EN 300 328 V2.2.2 (2019-11)	FCC:	FCC ID: 2AFZI-AVIBG21 FCC Part 15, Subpart B (Class B) FCC Part 15.247
		IC:	IC ID: 20544-AVIBG21 ICES-005, Issue 5, Dec. 2018 RSS-GEN Issue 5, Feb. 2021 Amendment 2 RSS-247 Issue 2, Feb. 2017
		BQB:	DID: D063032 Qualified Design ID (QDID): 205509 178212 175341

UL File E519564:

XACN/7 - Miscellaneous Controls, Automatic Electrical Controls

- UL 60730-1, 5th Ed., Issue Date: 2016-8-3
- - CAN/CSA E 60730-1:15, 5th Ed., AMD 2, Issue Date: 2015-12, Revision Date: 2017-10

UL 2043

- - Suitable for use in Plenums

FTBR/7 - Emergency Lighting Control Device

- - UL 924, Edition 10, Issue Date 2016-05-09, Revision Date 2022-12-14
- - CSA C22.2 NO. 141-15, 5th Ed., Issue Date: 2015-06-01